Wicomico County Public Schools

Lead in Water Testing Program - Phase #1

School sampling Completion Status

School Name	Initial Sample Date	# Initial samples	Elevated Samples			Follow up Sampling			
			Location	Results	Action Taken	Post Remediation First Draw Sample	Flush Sample	First Draw Sample	COMMENTS
Glen Avenue Elementary	5/2/2018	36	NONE	NONE	NONE				
Fruitland Primary	5/15/2018	31				9/13/2018			
			FPS 3a cafeteria short water fountain	46.9 ug/l	Fixture Replaced	1.18 ug/l	No Action Needed	No Action Needed	Back in Service
East Salisbury Elementary	5/17/2018	30				9/13/2018	10/5/2018	11/21/2018	
			ESES 3 Room 14	40.1 ug/l	Fixture Replaced	23.5 ug/l	2.73 ug/l	7.16 ug/l	Back in Service
			ESES 4 Room 15	54.9 ug/l	Fixture Replaced	33 ug/l	1.61 ug/l	1.32 ug/l	Back in Service
			ESES 5 Room 16	25 ug/l	Fixture Replaced	2.98 ug/l	No Action Needed	No Action Needed	Back in Service
			ESES 32 Room 30 sink right	25.2 ug/l	Fixture Replaced	15.6 ug/l	No Action Needed	No Action Needed	Back in Service
Wicomico Early Learning Ctr	5/17/2018	13	NONE	NONE	NONE				
Chipman Elementary	5/22/2018	32	NONE	NONE	NONE				
Delmar Elementary	5/24/2018	39					9/21/2018		
			DES 13 Classroom C-126	80.2 ug/l	Fixture Replaced	7.65 ug/l (6/7/18)	No Action Needed	No Action Needed	Back in Service
			DES 21 Classroom C-102	33.2 ug/l	Fixture Replaced	21.6 ug/l (9/13/18)			Taken Out of Service
			DES 32 Kitchen sink steamer faucet	40.9 ug/l	Fixture Replaced	87.5 ug/l (9/13/18)			Out of Service
			DES 36 Nurses office hand sink	28 ug/l	Fixture Replaced	1.62 ug/l (9/13/18)	No Action Needed	No Action Needed	Back in Service
North Salisbury Elementary	5/30/2018	44	NONE	NONE	NONE				
Pemberton Elementary	5/31/2018	53	NONE	NONE	NONE				
Pinehurst Elementary	6/5/2018	52				9/13/2018	10/5/2018	11/26/2018	
			PES-14 Class 205 right	21.3 ug/l	Fixture Replaced	2.43 ug/l	No Action Needed	No Action Needed	Back in Service
			PES-40 Classroom W-6 CF	20.2 ug/l	Fixture Replaced	29.0 ug/l	2.24 ug/l	No Action Needed	Back in Service
			PES-46 W9 sink left	20.9 ug/l	Fixture Replaced	41.8 ug/l	2.31 ug/l	13.0 ug/1	Back in Service
Fruitland Intermediate	6/6/2018	35							
			FIS-33 Communications Room 38 CS	159 ug/l	Fixture removed				Computer DVR Room, permanently removed.
Pittsville Elem-Middle	6/7/2018	19				9/13/2018	10/5/2018	11/21/2018	
			PEIS - 10 A20 sink for coffee	20.3 ug/l	Fixture Replaced	12.3 ug/l	No Action Needed	14.4 ug/l	Back in Service
			PEIS - 12 kitchen prep sink	110 ug/l	Fixture Replaced	82.4 ug/l	5.91 ug/l	30.1 ug/l	Out of Service, Further Investigation
			PEIS - 13 C5 prep sink #1 left	43.5 ug/l	Fixture Replaced	35.5 ug/l	28.9 ug/l	79.3 ug/l	Out of Service, Further Investigation. Bottled Water Supplied
			PEIS - 14 C5 prep sink #2 left	27.2 ug/l	Fixture Replaced	15.9 ug/l	Taken out of service	85 ug/l	Out of Service, Further Investigation. Bottled Water Supplied
			PEIS - 15 C5 prep sink #3 left	43.1 ug/l	Fixture Replaced	22.3 ug/l	22.4 ug/l	84.5 ug/l	Out of Service, Further Investigation. Bottled Water Supplied
			PEIS - 16 C5 prep sink #4 left	32.1 ug/l	Fixture Replaced	37.1 ug/l	6.74 ug/l	37.3 ug/l	Out of Service, Further Investigation. Bottled Water Supplied
Prince Street Elementary	6/13/2018	46	NONE	NONE	NONE				
Westside Intermediate	6/14/2018	60				9/13/2018			
			WIS - 22c Room C21	44.6 ug/l	Fixture Replaced	3.16 ug/l	No Action Needed	No Action Needed	Back in Service
			WIS -26e Room C27	36.7 ug/l	Fixture Replaced	1.4 ug/l	No Action Needed	No Action Needed	Back in Service
Revised Date 2/12/19									