

Wicomico County Public Schools
Lead in Water Testing Program - Phase #2
School Sampling Completion Status

School Name	Initial Sample Date	# Initial samples	Elevated Samples			Follow up Sampling				COMMENTS
			Location	Results	Action Taken	Post Remediation First Draw Sample	Secondary Remediation First Draw Sample	Tertiary Remediation First Draw Sample	Quaternary Remediation First Draw Sample	
Wicomico Early Learning Ctr		13				1/10/2019				
	5/16/2018	12								Test Results: No Actionable Levels
Additional Fixture located	12/6/2018	1	WELC 9b combo sink		Sink was not operable at time of 5/16/18 testing, replaced faucet for test	<1.0 ppb				Test Results: No Actionable Levels
Pinehurst Elementary		46				11/26/2018				
	6/4/2018	43								Test Results: No Actionable Levels
Additional Fixture located	6/4/2018	1	PES-14, Room 205 Combo Sink	21.3 ug/l	Fixture Replaced	2.43 ug/l				Back in Service
	6/4/2018	1	PES-46 W9 sink right	20.9 ug/l	Fixture Replaced	8.93 ug/l				Back in Service
	6/4/2018	1	PES-47, W6 Combo Sink	20.2 ug/l	Fixture Replaced					Taken Out of Service
Williards Elementary		66			12/17/18 thru 12/19/18	12/21/2018	1/16/2019	2/1/19 - 2/2/19	3/15/2019	
	11/21/2018	49								Test Results: No Actionable Levels
	11/21/2018	1	WES 2A Faucet, Rm #166	22.6 ug/l	Fixture Replaced	55.4 ug/l	18.5 ug/l			Back in Service
	11/21/2018	1	WES 2B Bubbler, Room #166	25.3 ug/l	Removed					Taken Out of Service
	11/21/2018	1	WES 3B Bubbler, Room #163	26.4 ug/l	Removed					Taken Out of Service
	11/21/2018	1	WES-5, Faucet, Room #159	26.3 ug/l	Fixture Replaced	67.5 ug/l	19.5 ug/l			Back in Service
	11/21/2018	1	WES-6B, Bubbler, Room #152	20.1 ug/l	Removed					Taken Out of Service
	11/21/2018	1	WES-15B, Bubbler, Room #226	21.6 ug/l	Removed					Taken Out of Service
	11/21/2018	1	WES-17A, Faucet, Room #130	27.2 ug/l	Fixture Replaced	44.0 ug/l	6.75 ug/l			Back in Service
	11/21/2018	1	WES-19, Bubbler, Room #181	23.3 ug/l	Fixture Replaced	13.0 ug/l				Back in Service
	11/21/2018	1	WES-20B, Bubbler, Room #128	25.5 ug/l	Removed					Taken Out of Service
	11/21/2018	1	WES-21B, Bubbler, Room #122	25.0 ug/l	Removed					Taken Out of Service
	11/21/2018	1	WES-23A, Faucet, Room #120	20.1 ug/l	Fixture Replaced	16.4 ug/l				Back in Service
	11/21/2018	1	WES-25 A. Faucet, Room #111	30.7 ug/l	Fixture Replaced	26.7 ug/l	26.9 ug/l	284.0 ug/l	9.0 ug/l	Back in Service
	11/21/2018	1	WES-25 B, Faucet, Room #114	30.9 ug/l	Fixture Replaced	9.47 ug/l				Back in Service
	11/21/2018	1	WES-27, Bubbler, Room #178	24.6 ug/l	Fixture Replaced	29.6 ug/l	22.9 ug/l	5.85 ug/l		Back in Service
	11/21/2018	1	WES-33, Prep Sink, Room #218	34.0 ug/l	Fixture Replaced	8.79 ug/l				Back in Service
	11/21/2018	1	WES-35A, Kitch. Lft. Faucet Room #218	31.4 ug/l	Fixture Replaced	31.4 ug/l	10.3 ug/l			Back in Service
	11/21/2018	1	WES-35B, Kitch. Rgt. Faucet, Room #218	70.7 ug/l	Fixture Replaced	39.8 ug/l	13.6 ug/l			Back in Service
Choices Academy		4					1/16/2010			
	12/6/2018	4		< 1.0 ppb						Test Results: No Actionable Levels
Parkside High School		129			1/22/2019	2/1/19 - 2/2/19				
	12/20/2018	30								Test Results: No Actionable Levels
	12/21/2018	77								Test Results: No Actionable Levels
	12/21/2018	1	Sample 33, Sink, Room U03	35.5 ug/l	Fixture Replaced					Hand Wash Only, Signage Installed
	12/21/2018	1	Sample 34, Sink, Room U04	25.1 ug/l	Fixture Replaced					Hand Wash Only, Signage Installed
	12/21/2018	1	Sample 35, Sink, Room U01	27.9 ug/l	Fixture Replaced					Hand Wash Only, Signage Installed
	12/21/2018	1	Sample 37, Sink Gooseneck, Room U13	119 ug/l	Fixture Replaced					Hand Wash Only, Signage Installed
	12/21/2018	1	Sample 71, Sink Gooseneck, Room K101	166 ug/l	Fixture Replaced					Hand Wash Only, Signage Installed
	12/21/2018	1	Sample 103, Sink, Room A12	93 ug/l	Fixture Replaced					Hand Wash Only, Signage Installed
	12/21/2018	1	Sample 104, Sink, Room A11	21.7 ug/l	Fixture Replaced					Hand Wash Only, Signage Installed
	12/21/2018	1	Sample 112, Sink, Room M28	234 ug/l	Fixture Replaced	1.43 ug/l				Back in Service
	12/21/2018	1	Sample 114, Sink, Room M33	42.9 ug/l	Fixture Replaced	3.49 ug/l				Back in Service
	1/4/2019	13								Test Results: No Actionable Levels
Wicomico High School		47				3/11/2019				

